



**Bureau Veritas Consumer
Products Services
Germany GmbH**

Businesspark A96
86842 Türkheim
Germany
+ 49 (0) 8245 96810-0
cps-tuerkheim@de.bureauveritas.com

Certificate of compliance

Applicant: Beijing Kinglong New Energy Technology Co., Ltd.
Building 4, Guiguliangcheng
No.1 Nongda South Road
Haidian
China

Product: Automatic disconnection device between a generator
and the public low-voltage grid

Model: Sunteams 1500, Sunteams 2000, Sunteams 3000

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with Engineering Recommendation G83/1 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with isolating function that can access the distribution network provider at any time.

Applied rules and standards :

DIN V VDE V 0126-1-1:2006-02 (Redundancy) and Engineering Recommendation G83/1:

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate of valid safety specifications for the specified use in accordance with regulations.

Report number: 11TH0096-G83
Certificate nummer: U11-227
Date of issue: 2011-03-22 **Valid until:** 2014-03-22

Achim Hänchen